



SPRINGFIELD UTILITY BOARD
 ENGINEERING STANDARD DISTRIBUTION
 PROCEDURES & POLICIES
 TEMPORARY MID-SPAN SUPPORTS

DATE | DWN | STD | CHK | APP
 3/25/2010 | SK | SK | EH | TJ

STANDARD NUMBER

ESD 0101

Page 1 of 2

NOTES:

1. Customer to provide minimum 4"x4" post or equivalent supported against service in both directions with 2"x4"x12' minimum.
2. Vertical clearance above ground shall be:
 - A. Minimum height at mid-span – 10 feet 6 inches
 - B. Minimum over residential driveways or commercial areas not subject to truck traffic – 16 feet
 - C. Minimum over roads, streets, alleys, and other areas subject to truck traffic – 16 feet 6 inches

REVISIONS	
Date	Description
8/23/83	Created
3/25/10	Reformatted, drawing updated



SPRINGFIELD UTILITY BOARD
ENGINEERING STANDARD DISTRIBUTION
PROCEDURES & POLICIES
TEMPORARY MID-SPAN SUPPORTS

DATE | DWN | STD | CHK | APP
3/25/2010 | SK | SK | EH | TJ

STANDARD NUMBER

ESD 0101

Page 2 of 2