



SPRINGFIELD UTILITY BOARD
 ENGINEERING STANDARD DISTRIBUTION
 PROCEDURES & POLICIES
 TYPICAL UNDERGROUND MOBILE HOME SERVICE

DATE | DWN | STD | CHK | APP
 6/15/2010 | SK | SK | EH | TJ

STANDARD NUMBER

ESD 0107

Page 1 of 2

NOTES:

1. Approved service equipment provided by customer includes conduit, meter base, ground rod and conductors.
2. Customer installed and maintained trench and conductors beyond point of delivery (load side of meter) subject to City of Springfield approval.
3. Refer to ESD 0090 for details regarding S.U.B. requirements for meter installations. Meter location subject to approval by S.U.B.
4. Customer to provide and install pressure treated post not less than 6" x 6" square or 5-1/2" diameter set 36" minimum in the ground.
5. Meter height to center of meter shall be 5' to 6'.

REVISIONS	
Date	Description
8/24/83	Created
6/15/10	Reformatted, drawing updated



SPRINGFIELD UTILITY BOARD
ENGINEERING STANDARD DISTRIBUTION
PROCEDURES & POLICIES
TYPICAL UNDERGROUND MOBILE HOME SERVICE

DATE | DWN | STD | CHK | APP
6/15/2010 | SK | SK | EH | TJ

STANDARD NUMBER

ESD 0107

Page 2 of 2