
**SUB WATER DIVISION
MEMORANDUM**

TO: All concerned parties

FROM: Springfield Utility Board Water Division

DATE: March 29, 2013

SUBJECT: **Revision 1. WSC Standard Specifications and Drawings update.**

The following items were updated in the Standard Construction Specifications for the purposes of an annual review and preparing the documents for use on the Springfield Utility Board website.

- General formatting and grammar correction for all sections (W-100's to W400's)
- Replace existing standard drawings in their entirety
- Renumber all standard drawing references in W-400's to match new standard drawing numbers.
- Revised W-401.02.02G to include SDR11 HDPE.
- Revised W-401.02.02H to change acceptable wire specification.
- Revised W-401.02.08B to add Ford as an acceptable ball valve manufacturer.
- Revised W-401.03.09 – Table I to show proper deflection parameters.
- Revised W-401.03.10A to adjust acceptable hydrant installation location.
- Revised W-401.03.10B to show standard detail reference.
- Revised W-401.03.10C to add “as directed by Engineer” verbiage.
- Revised W-401.03.10H to reflect new 1” service tap minimum standard.
- Revised W-401.03.15 to add verbiage pertaining to contractor requirements when sterilizing facilities.
- Revised W-401.04.01B to the latest allowable leakage formula per June 2012 AWWA standards.