
	<p align="center"> <b>SPRINGFIELD UTILITY BOARD</b>          ENGINEERING STANDARD DISTRIBUTION          PROCEDURES &amp; POLICIES          TEMPORARY MID-SPAN SUPPORTS       </p>	<p align="right"> <small>           DATE   DWN   STD   CHK   APP            3/25/2010   SK   SK   EH   TJ            12/26/2018   RJE   TGP   NA   SK            STANDARD NUMBER  <b>ESD 0101</b>            Page 1 of 2         </small> </p>
---	---	--

NOTES:

1. Customer to provide minimum 4"x4" post or equivalent supported against service in both directions with 2"x4"x12' minimum.
2. Vertical clearance above ground shall be:
  - A. Minimum over pedestrian accessible areas only – 12 feet 6 inches
  - B. Minimum over residential driveways or commercial areas not subject to truck traffic – 16 feet 6 inches
  - C. Minimum over roads, streets, alleys, and other areas subject to truck traffic – 16 feet 6 inches
3. Temporary services shall be energized for a maximum of 6 months from the date of initial connection

REVISIONS	
Date	Description
8/23/83	Created
3/25/10	Reformatted, drawing updated
12/17/18	Changed note 2A, added note 3, modified 2B to reflect a 16 feet 6 inch clearance

	<p><b>SPRINGFIELD UTILITY BOARD</b>          ENGINEERING STANDARD DISTRIBUTION          PROCEDURES &amp; POLICIES          TEMPORARY MID-SPAN SUPPORTS</p>	<p><u>DATE   DWN   STD   CHK   APP</u>  <u>3/25/2010   SK   SK   EH   TJ</u>  <u>12/26/2018   RJE   TGP   NA   SK</u></p> <p>STANDARD NUMBER  <b>ESD 0101</b>          Page 2 of 2</p>
---	--	--