



	<p><b>SPRINGFIELD UTILITY BOARD</b>  ENGINEERING STANDARD DISTRIBUTION  PROCEDURES &amp; POLICIES  UNDERGROUND METER POST SERVICE</p>	<p>DATE   DWN   STD   CHK   APP  <u>6/15/2010</u>   SK   SK   EH   TJ  <u>12/26/2018</u>   RJE   TGP   NA   SK</p> <p>STANDARD NUMBER  <b>ESD 0107</b>  Page 1 of 2</p>
---	---	---

NOTES:

1. Approved service equipment provided by customer includes conduit, meter base, ground rod and conductors.
2. Customer installed and maintained trench and conductors beyond point of delivery (load side of meter) subject to City of Springfield approval.
3. Refer to ESD 0090 for details regarding S.U.B. requirements for meter installations. Meter location subject to approval by S.U.B.
4. Customer to provide and install pressure treated post not less than 6" x 6" square or 5-1/2" diameter set 36" minimum in the ground.
5. Meter height to center of meter shall be 5' to 6'.

REVISIONS	
Date	Description
8/24/83	Created
6/15/10	Reformatted, drawing updated
12/17/2018	Removed "Mobile Home" from title, added "meter post" to title