



NOTES:

1. MINIMUM 12" SEPARATION BETWEEN WATER AND OTHER DUCTS.
2. NO DUCTS MAY BE PLACED ABOVE THE WATER MAIN.
3. FOR ADDITIONAL TRENCH SECTION INFORMATION REFER TO WSC STD. DWG. W1.17.

SCALE: N.T.S.
DRAWN BY: LSB
CONSTRUCTION: <i>SS</i>
ENGINEERING: <i>US</i>



WATER DIVISION STANDARD DRAWING
TYPICAL JOINT TRENCH DETAIL

DRAWING NUMBER
W1.29
REVISED: 1-15-2013

NOTE:

THE REFERENCES PROVIDED BELOW ARE FOR INFORMATIONAL PURPOSES ONLY AND MAY NOT BE COMPLETE. IT IS THE CONTRACTORS RESPONSIBILITY TO ENSURE THAT ANY INSTALLATION PERFORMED MEETS THE REQUIREMENTS SET FORTH IN THE STANDARD CONSTRUCTION SPECIFICATIONS.

SUB WATER DEPARTMENT STANDARD CONSTRUCTION SPECIFICATION REFERENCES:

TRENCHING AND BACKFILL: DIVISION W-300